

TIER 3 PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Mayer DWID

Our water system violated drinking water standards in 2018. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

Due to internal scheduling conflicts within ADEQ, during the 4th quarter of 2018 and the 1st quarter of 2019, the contaminants listed below were not taken during the specified time frame.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) that were not properly tested for during the last year; how often each are supposed to be sampled and how many samples were supposed to be taken; how many samples we took; when samples should have been taken; and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were taken
DBP2	4 th quarter – 2018	2	November	October
DBP2	1 st quarter - 2019	2	February	January

What is being done?

Samples are scheduled to be taken by the system as part of a DBP2 MCL exceedance which occurred during the 3rd quarter of 2018. Quarterly samples are to be taken every 90 days +/- 2 days until they can achieve 4 consecutive quarters as required by rule.

For more information, please contact Mayer DWID (928)632-4113.

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Mayer DWID
State Water System ID#: 13039
Date distributed: 5/10/19